BSI-inspectorate America 178 Mortland Road Searsport, Maine 04974 (207)548-6440



QUALITY CERTIFICATE

Vessel Customer

Operation

SHORE TANK NO. 3

SPRAGUE

Port Date BUCKSPORT, MAINE

May 19, 2003

Reference

Report **SP/03/0513**

ANALYSIS

Terminal

SPRAGUE

Sample # 287355

Name of material being tested Description of sample source Samples Drawn by (company) Samples Tested by (company)

NO. 6 FUEL OIL 0.5%

EX. SHORE TANK NO. 3 AFTER DISCHARGE OF PENN 90 INSPECTORATE INSPECTORATE

Tests being Performed	Test method	Minimum	Maximum	Sample Source
GRAVITY, API @ 60 F FLASH POINT, F VISCOSITY, SSF @ 122 F POUR POINT, F WATER & SEDIMENT, % VOL. SULPHUR, % WT. ASH, % WT. VANADIUM, PPM SODIUM, PPM BTU'S/POUND BTU'S/GALLON NITROGEN, % WT. CARBON RESIDUE, % WT. ASPHALTENES, % WT.	ASTM D 4052 ASTM D 93 ASTM D 445/2161 ASTM D 97 ASTM D 1796 ASTM D 4294 ASTM D 482 AA/AE CALCULATION CONVERSION ASTM D 3228 ASTM D 4530 IP-143	Minimum	Maximum	11.6 200+ 66.4 +33.8 0.10 0.436 0.079 8 13 18,527 152,570 0.395 6.74 1.53
TAT ATTACHED COAT I THE INSPECTION TO BE OF THE INSPECT GUTTERCATE IN THE TABLE TATED BY THE INSPECT BEPRESENTS THAT ANY PRODUCT IT MAY SELL AT FROM SUCH INSPECTION CERTIFICATE BUT SUCH MEET THE SPECIFICATIONS AS MAY BE REQUIRED REGULATIONS WITHIN THE STATE THAT THE PROD	PRODUCT SHALL			

DENNIS E. CURTIS

Inspectorate America Corp (Searsport, Me.)